



ANSI/EIA-364-101-2000
Approved: March 10, 2000

EIA STANDARD

EIA-364-101

TP-101

Attenuation Test Procedure for Electrical Connectors, Sockets, Cable Assemblies or Interconnection Systems

EIA-364-101

MAY 2000



Electronic Components, Assemblies & Materials Association

ELECTRONIC COMPONENTS, ASSEMBLIES & MATERIALS
ASSOCIATION
THE ELECTRONIC COMPONENT SECTOR OF THE ELECTRONIC INDUSTRIES ALLIANCE



NOTICE

EIA Engineering Standards and Publications are designed to serve the public interest through eliminating misunderstandings between manufacturers and purchasers, facilitating interchangeability and improvement of products, and assisting the purchaser in selecting and obtaining with minimum delay the proper product for his particular need. Existence of such Standards and Publications shall not in any respect preclude any member or nonmember of EIA from manufacturing or selling products not conforming to such Standards and Publications, nor shall the existence of such Standards and Publications preclude their voluntary use by those other than EIA members, whether the standard is to be used either domestically or internationally.

Standards and Publications are adopted by EIA in accordance with the American National Standards Institute (ANSI) patent policy. By such action, EIA does not assume any liability to any patent owner, nor does it assume any obligation whatever to parties adopting the Standard or Publication.

This EIA Standard is considered to have International Standardization implication, but the International Electrotechnical Commission activity has not progressed to the point where a valid comparison between the EIA Standard and the IEC document can be made.

This Standard does not purport to address all safety problems associated with its use or all applicable regulatory requirements. It is the responsibility of the user of this Standard to establish appropriate safety and health practices and to determine the applicability of regulatory limitations before its use.

(From Standards Proposal Number 4153-A, formulated under the cognizance of the CE-2.0 National Connector Standards Committee.)

Published by

©ELECTRONIC INDUSTRIES ALLIANCE 2000
Technology Strategy & Standards Department
2500 Wilson Boulevard
Arlington, VA 22201

**PRICE: Please refer to the current
Catalog of EIA Electronic Industries Alliance Standards and Engineering Publications
or call Global Engineering Documents, USA and Canada (1-800-854-7179)
International (303-397-7956)**

All rights reserved
Printed in U.S.A.

PLEASE!

**DON'T VIOLATE
THE
LAW!**

This document is copyrighted by the EIA and may not be reproduced without permission.

Organizations may obtain permission to reproduce a limited number of copies through entering into a license agreement. For information, contact:

Global Engineering Documents
15 Inverness Way East
Englewood, CO 80112-5704 or call
U.S.A. and Canada 1-800-854-7179, International (303) 397-7956

CONTENTS

Clause		Page
1	Introduction	1
1.1	Scope	1
1.2	Object	1
1.3	Definitions	1
2	Test resources	1
2.1	Equipment	1
2.2	Fixture	2
3	Test specimen	3
3.1	Description	3
4	Test procedure	4
4.1	Fixture attenuation	4
4.2	Method A, frequency domain	4
4.3	Method B, time domain	7
5	Details to be specified	7
6	Test documentation	8
Figure		
A.1	Technique diagrams	A-1
A.2	Single-ended terminations	A-2
A.3	Differential (balanced) terminations	A-3
A.4	Example of specimen in fixture for attenuation	A-3
Annex		
A	Normative	A-1
B	Informative	B-1

(This page left blank)

TEST PROCEDURE No. 101
ATTENUATION TEST PROCEDURE
FOR
ELECTRICAL CONNECTORS, SOCKETS,
CABLE ASSEMBLIES OR INTERCONNECTION SYSTEMS

(From EIA Standards Proposal No. 4153-A, formulated under the cognizance EIA CE-2.0 Committee on National Connector Standards.)

1 Introduction

1.1 Scope

This standard is applicable to electrical connectors, sockets, cable assemblies or interconnection systems.

1.2 Object

This standard describes one time and two frequency domain methods to measure attenuation as a function of frequency.

1.3 Definitions

1.3.1 Attenuation

The reduction of average power during the transmission from the input to the output of the specimen, usually measured in decibels (dB)

1.3.2 Specimen environment impedance

The impedance presented to the signal conductors by the fixture. This impedance is a result of transmission lines, termination resistors, attached receivers or signal sources, and fixture parasitics.

2 Test resources

2.1 Equipment

2.1.1 Frequency domain

A network analyzer is preferred. When greater dynamic range is required, a signal generator and spectrum analyzer may be used. For differential measurements, an 8 port network analyzer or baluns may be used. For the Open/Short method, an impedance or vector network analyzer may be used.

2.1.2 Time domain

A time domain reflectometer (TDR), triggered impulse generator, and appropriate fast fourier transform (FFT) software shall be used.

2.2 Fixture

Unless otherwise specified in the referencing document the specimen environment impedance shall match the impedance of the test equipment. Typically this will be 50 ohms for single-ended measurements and 100 ohms for differential.

2.2.1 Specimen conductor assignments

2.2.1.1 For each measurement, the line to be measured shall be fixtured as indicated in the referencing document. The far end (destination) and the near end (driven) of the line shall be terminated in the specimen environment impedance specified using one of the methods in figures A.2 or A.3.

NOTE — For the Open/Short method, the far end of the specimen is not terminated, but means must be available to connect both an open and a short circuit to the far end of the specimen.

2.2.1.2 In the special case where the drive signal is differential and not balanced, the common mode energy shall be terminated. Adjacent signal lines to these should likewise be terminated if possible. Note, electrically long adjacent signal lines may resonate, adding error to the results. Unless otherwise specified a 1:1 signal to ground ratio (2:1 if differential measurements are performed) shall be used with each end having all grounds commoned. (For an example, see figure A.4.).

2.2.2 Specimen fixture and signal line terminations for specimen environment impedance

Care should be taken to minimize the reactances of the resistive terminations over the range of test frequencies.

NOTE — The fixture geometry and materials may impact the measurements due to the fixture parasitics. Usually the product's intended use dictates the most meaningful way to fixture it.

2.2.3 Insertion technique

The fixture shall be designed to allow measurement of attenuation with and without the specimen; see figure A.1.a. If baluns are used for a measurement, or minimum loss pads used for impedance matching, these are included in the fixture. Figures A.2 and A.3. show typical configurations with minimum loss pads.

2.2.4 Reference fixture technique

In this technique a separate fixture that combines both near end and far end is used for the fixture attenuation measurement; see figure A.1.b. This fixture shall be a duplicate of the specimen fixture, only without the specimen. Traces, if used, shall include fixture connectors, vias, bends, and corners. If baluns are used for a differential measurement, or minimum loss pads used for impedance matching, these are included in the fixturing. Figures A.2 and A.3. show typical configurations with minimum loss pads.

3 Test Specimen

3.1 Description

For this test procedure the test specimen shall be as follows:

NOTE — As the specimen length approaches $\frac{1}{4}$ wavelength, careful interpretation of the results is required due to possible resonance effects. It is recommended that the specimen electrical length be $< \frac{1}{8}$ the wavelength of the maximum test frequency.

3.1.1 Separable connectors

A mated pair with identified signals and grounds.

3.1.2 Cable assembly

Assembled connectors and cable, and mating connector(s) with identified signal and ground contacts and wires.

3.1.3 Sockets

A socket and test device or a socket and pluggable header adapter with identified signal and grounds.

4 Test procedure

Unless otherwise specified all measurement results shall contain a minimum of 200 frequency points. Each fixture measurement and its associated specimen attenuation measurement shall be taken at the same frequencies. Generate a magnitude versus frequency plot; 1 dB per division vertical scale and log frequency sweep are recommended. When applicable, single frequency results shall be tabulated, as specified in the referencing document. Place the specimen a minimum of 5 cm from any objects that would affect measured results.

NOTE — The test professional should be aware of limitations of any math operation performed by an instrument, (e.g. normalization or software filtering).

4.1 Fixture attenuation

Fixture attenuation shall be measured separately so that it can be removed from and compared to the specimen measurement. If the referencing document precisely specifies the fixture so that its attenuation contribution is fixed, then the fixture attenuation measurement is optional.

NOTES — Results may be inaccurate when:

- 1 The fixture attenuation is greater than the specimen attenuation.
- 2 The fixture electrical length is greater than $1/8$ wavelength at the highest test frequency, unless special precautions are taken to ensure good impedance matching throughout the measurement path. This can be confirmed by sweeping across a wide frequency range and observing if there are nulls due to moding, fixture or balun resonances, etc.

4.2 Method A, frequency domain

4.2.1 Network or spectrum analyzer (direct technique)

4.2.1.1 Calibration

4.2.1.1.1 When using a network analyzer, at a minimum, a "through" calibration at the reference plane (include analyzer cables but not specimen fixture) shall be performed. Where possible a 12 term calibration is recommended.

4.2.1.1.2 When using a spectrum analyzer and signal generator, take a reference measurement similarly. The generator output shall be kept the same for both fixture and specimen-with-fixture attenuation measurements made later.

4.2.1.2 Insertion technique

4.2.1.2.1 Assemble the fixture so that the near end is connected to the far end without the specimen in between; see figure A.1.a. Connect the network analyzer ports, or the signal generator and spectrum analyzer, to the appropriate locations of the driven line fixture.

4.2.1.2.2 When using a network analyzer measure the fixture attenuation (S_{21}).

4.2.1.2.3 When using a spectrum analyzer, measure the power from the generator through the fixture. Then divide the magnitude of this signal by that of the reference measurement performed in 4.2.1.1.2 at each frequency (subtract dB). This is the fixture attenuation.

4.2.1.3 Reference fixture technique

4.2.1.3.1 Construct a reference fixture that duplicates the specimen fixture but without the specimen. Include both near and far ends; see figure A.1.b. Connect the network analyzer ports, or the signal generator and spectrum analyzer to the appropriate locations of the driven line fixture.

4.2.1.3.2 When using a network analyzer, measure the fixture attenuation (S_{21}).

4.2.1.3.3 When using a spectrum analyzer, measure the power from the generator through the fixture. Then divide the magnitude of this signal by that of the reference measurement performed in 4.2.1.2.3 at each frequency (subtract dB). This is the fixture attenuation.

4.2.1.4 Specimen attenuation measurement

4.2.1.4.1 Add specimen to fixture.

4.2.1.4.2 When using a network analyzer, connect the analyzer drive port to the near end of the fixture and the receiver port of the analyzer to the far end of the fixture. Measure the specimen-with-fixture attenuation in dB.

4.2.1.4.3 When using a spectrum analyzer, connect the generator output port to the near end of the fixture and the analyzer input to the far end of the fixture. Measure the signal power (typically in dBm). Divide the magnitude of this signal by that of the reference measurement, see 4.2.1.1.2, at each frequency (subtract dBm). Record specimen-with-fixture results in dB.

4.2.1.5 Divide the specimen-with-fixture attenuation by the fixture attenuation (subtract dB) and plot. This is the specimen attenuation. Record single frequency results and tabulate, if requested.

4.2.2 Impedance analyzer (open/short method)

4.2.2.1 Calibrate the instrument according to the manufacturer's instructions. This is typically done using short and open circuit standards connected one at a time at the specimen measurement location of the fixture.

4.2.2.2 Connect the specimen to the fixture with the far end of the specimen open-circuited, and measure the magnitude and phase of the specimen plus fixture impedance.

4.2.2.3 Short-circuit the far end of the specimen, and measure the magnitude and phase of the specimen plus fixture impedance.

4.2.2.4 Calculate the attenuation of the specimen plus fixture using the following equations: ¹⁾

$$P = (|Z_{OP}| / |Z_{ST}|)^{1/2} \text{ and } \phi = (\theta_{ST} - \theta_{OP}) / 2,$$

where:

Z_{OP} and θ_{OP} are the open-circuit impedance and phase, respectively, and Z_{ST} and θ_{ST} are the short-circuit impedance and phase, respectively. The attenuation constant,

$$\alpha = 8.6859 (1/2l) \ln [((1+x)^2 + y^2) / ((1-x)^2 + y^2)]^{1/2} \text{ dB/m},$$

where:

l = specimen physical length (meters)

$x = P \cos \phi$

$y = P \sin \phi$

4.2.2.5 Divide the specimen-with-fixture attenuation by the fixture attenuation (subtract dB) and plot. This is the specimen attenuation. Record single frequency results and tabulate, if requested.

4.2.3 Additional measurements

Repeat this entire procedure for each measurement requested.

1) Procedure and equations from "Measuring Cable Parameters," Hewlett-Packard Application Note 380-2, p.15.

4.3 Method B, time domain

This method requires that the network analyzer procedure be followed, but with the following changes. A TDR in time domain transmission (TDT) mode with a triggered short impulse generator to measure the response of the specimen to an impulse stimulus shall be used. Fast fourier transform (FFT) software is used to compute the attenuation of the specimen in the frequency domain.

4.3.1 Connect the TDR output to the input of an impulse generator.

4.3.2 Connect the output of the impulse generator to the near end of the test fixture, and connect the far end of the test fixture to the input of a TDR sampling head.

4.3.3 For each measurement, measure the TDT response to the impulse stimulus.

4.3.4 Compute the FFT of the time domain response, the result being the attenuation in the frequency domain. From these data the complex propagation constants alpha (attenuation versus frequency) and beta (phase versus frequency) may be calculated over a very wide frequency range. If combined with low frequency capacitance measurements, the specimen may be completely characterized, including attenuation as well as complex impedance as functions of frequency.

5 Details to be specified

The following details shall be specified in the referencing document:

5.1 Method to be used, time or frequency domain

5.2 Specimen signal and ground assignments for each measurement. As a minimum, the driven conductor or conductor pair, the nearest signal conductors in each direction, and the associated (adjacent) grounds of all these, shall be identified.

NOTE — A sufficient number of lines to be measured based on a consideration of geometry, should be specified so that the best and worst case performance will be determined. It is recommended that the following be considered: conductor spacing, conductor orientation, conductor length, etc.

5.3 The type of drive signal, single-ended or differential. Refer to 2.2.1 in the special case of differential and not balanced signals.

5.4 Specimen environment impedance if other than 50 ohms for single-ended or 100 ohms for differential.

5.5 Points between which the attenuation shall be measured

5.6 Measurement frequency range

5.7 Tabulated single frequency results, if desired

5.8 Plot magnitude format, if other than dB and log frequency

5.9 Any special requirements with respect to fixture and termination construction and electrical properties.

5.10 Any special calibration technique

6 Test documentation

Documentation shall contain the details specified in clause 5, with any exceptions, and the following:

6.1 Title of test

6.2 Test equipment used, and date of last and next calibration

6.3 Measured fixture, measured specimen-with-fixture, and calculated specimen attenuation plots and tabulated single frequency results.

6.4 Balun specifications, if used

6.5 Test method used, time domain or frequency domain, (direct or open/short)

6.6 Observations

6.7 Name of operator and date of test

Annex

A Normative




Figure A.1 - Technique diagrams




Figure A.2 – Single-ended terminations




Figure A.3 - Differential (balanced) terminations




Figure A.4 - Example of specimen in fixture for attenuation

B Informative

B.1 Practical guidance

Near perfect resistive terminations of the signal lines may not be possible at high frequencies due to parasitic reactances in both signal and ground conductors. These reactances will have an impact on measured results. In this case it is desirable that the test fixture duplicate the exact geometry (parasitics) of the actual application. This may involve the use of transmission lines in addition to the components of figures A.1 and A.2. Most instruments used for these measurements are internally terminated in 50 ohms at both source and detector ports.

EIA Document Improvement Proposal

If in the review or use of this document, a potential change is made evident for safety, health or technical reasons, please fill in the appropriate information below and mail or FAX to:

Electronic Industries Alliance
Engineering Department – Publications Office
2500 Wilson Blvd.
Arlington, VA 22201
FAX: (703) 907-7501

Document No.	Document Title:
Submitter's Name:	Telephone No.: FAX No.: e-mail:
Address:	
Urgency of Change: Immediate: <input type="checkbox"/> At next revision: <input type="checkbox"/>	
Problem Area: a. Clause Number and/or Drawing: b. Recommended Changes: c. Reason/Rationale for Recommendation:	
Additional Remarks:	
Signature:	Date:
FOR EIA USE ONLY	
Responsible Committee: Chairman: Date comments forwarded to Committee Chairman:	

