



ANSI/EIA-364-45A-2000

Approved: May 3, 2000

EIA-364-45A

EIA STANDARD

TP-45A

Firewall Flame Test Procedure for Electrical Connectors

EIA-364-45A

(Revision of EIA-364-45)

MAY 2000



Electronic Components, Assemblies & Materials Association

ELECTRONIC COMPONENT, ASSEMBLIES & MATERIALS
ASSOCIATION

THE ELECTRONIC COMPONENT SECTOR OF THE ELECTRONIC INDUSTRIES ALLIANCE



Electronic Industries Alliance

NOTICE

EIA Engineering Standards and Publications are designed to serve the public interest through eliminating misunderstandings between manufacturers and purchasers, facilitating interchangeability and improvement of products, and assisting the purchaser in selecting and obtaining with minimum delay the proper product for his particular need. Existence of such Standards and Publications shall not in any respect preclude any member or nonmember of EIA from manufacturing or selling products not conforming to such Standards and Publications, nor shall the existence of such Standards and Publications preclude their voluntary use by those other than EIA members, whether the standard is to be used either domestically or internationally.

Standards and Publications are adopted by EIA in accordance with the American National Standards Institute (ANSI) patent policy. By such action, EIA does not assume any liability to any patent owner, nor does it assume any obligation whatever to parties adopting the Standard or Publication.

This EIA Standard is considered to have International Standardization implication, but the International Electrotechnical Commission activity has not progressed to the point where a valid comparison between the EIA Standard and the IEC document can be made.

This Standard does not purport to address all safety problems associated with its use or all applicable regulatory requirements. It is the responsibility of the user of this Standard to establish appropriate safety and health practices and to determine the applicability of regulatory limitations before its use.

(From Project Number 4524-A, formulated under the cognizance of the CE-2.0 National Connector Standards Committee.)

Published by

©ELECTRONIC INDUSTRIES ALLIANCE 2000
Technology Strategy & Standards Department
2500 Wilson Boulevard
Arlington, VA 22201

**PRICE: Please refer to the current
Catalog of EIA Electronic Industries Alliance Standards and Engineering Publications
or call Global Engineering Documents, USA and Canada (1-800-854-7179)
International (303-397-7956)**

All rights reserved
Printed in U.S.A.

PLEASE!

DON'T VIOLATE
THE
LAW!

This document is copyrighted by the EIA and may not be reproduced without permission.

Organizations may obtain permission to reproduce a limited number of copies through entering into a license agreement. For information, contact:

Global Engineering Documents
15 Inverness Way East
Englewood, CO 80112-5704 or call
U.S.A. and Canada 1-800-854-7179, International (303) 397-7956

CONTENTS

Clause		Page
1	Introduction	1
1.1	Scope	1
2	Test resources	1
2.1	Equipment	1
2.2	Material	2
3	Test specimen	2
3.1	Description	2
3.2	Preparation	2
4	Test procedure	3
4.1	Electrical tests	2
4.2	Test conditions	2
4.3	Post test examination	2
5	Details to be specified	4
6	Test documentation	5
Figure		
1	Thermocouple details	5
2	Firewall connector fixture details	6
3	Firewall connector fixture assembly	7
4	Firewall connector test setup	8
5	Schematic circuit for testing firewall connectors	9
Table		
1	Connector test currents	4

(This page left blank)

TEST PROCEDURE No. 45A
FIREWALL FLAME TEST PROCEDURE
FOR
ELECTRICAL CONNECTORS

(From EIA Standards Proposal No. 4524-A, formulated under the cognizance EIA CE-2.0 Committee on National Connector Standards, and previously published in EIA-364-45.)

1 Introduction

1.1 Scope

This standard establishes a test method to determine the ability of a mated electrical firewall connector to resist specified flame and vibration during a 20 minute exposure by preventing the flame from breaching the firewall through the connector, and providing specified electrical performance for the first 6 minutes of the 20 minute exposure.

NOTE — Do not use this test procedure to describe or appraise the fire hazard or fire risk of the materials, products or assemblies under actual fire conditions. Each application should be assessed for compatibility with electrical and circuit requirements.

CAUTION —

- 1 This procedure may involve hazardous materials, operations, and equipment. This procedure does not purport to address all safety problems associated with its use or all regulatory requirements. It is the responsibility of the user of this procedure to establish appropriate safety and health practices and to determine the applicability or regulatory limitations before its use.
- 2 This test should be conducted in a well ventilated area to avoid inhalation of smoke and toxic products of combustion. Protect personnel and equipment from risk of fire.

2 Test resources

2.1 Equipment

2.1.1 An inspirator torch capable of producing and maintaining a flame at a constant temperature of $1100\text{ }^{\circ}\text{C} \pm 25\text{ }^{\circ}\text{C}$ ($2012\text{ }^{\circ}\text{F} \pm 45\text{ }^{\circ}\text{F}$) from propane or natural gas with a flow rate equivalent to an input of $3.48 \times 10^7\text{ J/h}$ to $3.90 \times 10^7\text{ J/h}$ (33,000 Btu/h to 37,000 Btu/h). Primary cone diameter shall be 12.7 mm - 19 mm (0.50 inch - 0.75 inch) at nozzle. Secondary cone shall engulf or provide representative impingement coverage, dependent on size of the test sample.

2.1.2 A gas flowmeter with an accuracy of $\pm 1\%$ full scale.

2.1.3 A thermocouple with an exposure junction as shown in figure 1 and temperature meter capable of continuously measuring $1100\text{ }^{\circ}\text{C} \pm 25\text{ }^{\circ}\text{C}$ ($2012\text{ }^{\circ}\text{F} \pm 45\text{ }^{\circ}\text{F}$) with an accuracy of 1% of the reading.

2.1.4 A firewall test fixture as shown in figures 2, 3 and 4.

2.1.5 Vibration equipment capable of vibrating the connector and test fixture continuously at 33 Hz with a total excursion of 6.3 millimeters (0.25 inch).

2.1.6 DC power supply with a maximum open circuit voltage of 28 volts capable of producing test currents between 5 amperes and 150 amperes.

2.1.7 A center-tapped transformer ac power supply capable of producing 110/220 to 130/260 volts at 50 Hz to 60 Hz capable of delivering a minimum current of 2 amperes.

2.1.8 A multirange undamped dc ammeter with an accuracy of 1% full scale and capable of measuring dc currents between 5 amperes and 150 amperes.

2.1.9 Two ac ammeters, with an accuracy of $\pm 1\%$ capable of measuring 2 amperes.

2.2 Material

2.2.1 Fiberglass wrap (untreated glass tape) or equivalent; see figure 4

3 Test specimen

3.1 Description

The test sample shall be wired mated and torqued connectors, complete with accessories having straight saddle bar cable clamps.

3.2 Preparation

3.2.1 Connect alternate contacts into two series groups, see figure 5, with wire suitable for high temperature application.

3.2.2 Thoroughly clean the test sample of oil, grease, dirt and other foreign matter using a noncombustible solvent.

3.2.3 Wrap wire bundles with plain fiberglass wrap (untreated glass tape); see figure 4, or other suitable means to protect the wire from the flame and to stabilize the wire bundle-connector interface during flame and vibration application. Protective wrap should be as close as possible to the rear of the connector dielectric and under the cable clamp. Protective wrap shall extend 178 mm (7 inches) minimum from the rear of the saddle clamp on the plug.

4 Test procedure

4.1 Attach the test sample to the connector mounting plate shown in figures 2, 3 and 4.

4.2 Attach the mounting plate and thermal insulator sheet to the firewall test fixture as shown in figure 3.

4.3 Mount the firewall test fixture on the vibration machine table as shown in figure 4.

4.4 Support the wire bundles on both sides of the connector to stationary structure 200 mm to 250 mm (8 inches to 10 inches) from the connector backshell.

4.5 Connect the wired connector to the circuit shown in figure 5 to test the connector's electrical integrity in accordance with 4.11.

4.6 The connector shall be solidly grounded during the entire test.

4.7 Position the thermocouple with respect to the coupling nut of the connector as shown in figure 4.

4.8 With the torch and thermocouple moved away from the connector (flame not contacting connector) ignite the gas. Adjust the flow of gas for 3.48×10^7 J/h to 3.90×10^7 J/h (33,000 Btu/h to 37,000 Btu/h) and a flame temperature of $1100 \text{ }^\circ\text{C} \pm 25 \text{ }^\circ\text{C}$ ($2012 \text{ }^\circ\text{F} \pm 45 \text{ }^\circ\text{F}$). Position the torch so that the thermocouple measures the hot spot of the flame.

4.9 Load all contacts with the dc current shown in table 1. Do not alter the current during the test.

4.10 Start the vibration machine and vibrate continuously at 33 Hz with a total excursion of 6.3 millimeters (0.25 inch).

4.11 Flame and vibration test (20 minutes total)

4.11.1 Move the torch and thermocouple to the position shown in figure 4. When the thermocouple reaches $1100 \text{ }^\circ\text{C} \pm 25 \text{ }^\circ\text{C}$ ($2012 \text{ }^\circ\text{F} \pm 45 \text{ }^\circ\text{F}$), start the 20 minute test. Continuously monitor the gas flow and temperature.

4.11.2 Observe and record the presence of flame, for any reason or from any source, on the protected side of the firewall test fixture during the entire 20 minutes of flame exposure.

4.12 Electrical performance test, figure 5 (six minutes)

4.12.1 During the first five minutes of combined flame and vibration with switch 1 closed, apply specified dc test current, table 1, through all contacts. Monitor the ammeter for fluctuations indicating current discontinuities which shall not drop below 10% of initial value.

Table 1 – Connector test currents

Contact size	DC test currents, amperes
22	5.0
20	7.5
16	13
12	23
8	46
4	80
0	150

4.12.2 At the end of five minutes, disconnect the dc power and its load by opening switch 1.

4.12.3 Apply ac voltage for one minute between each group of contacts and the shell by closing switch 2. Observe the ammeters for leakage currents, which should not exceed two amperes.

4.13 Flame and vibration, continued (14 minutes)

At the end of six minutes remove the ac potential and continue flame and vibration for another 14 minutes for a total elapsed time of 20 minutes.

5 Details to be specified

The following details shall be specified in the referencing document:

5.1 Connector assembly including backshells, cable clamps and accessories

5.2 Special mounting and torque requirements, if applicable

5.3 Vibration frequency if other than 33 Hz

5.4 Voltage and test currents, if other than specified herein.

6 Documentation

Documentation shall contain the details specified in clause 5, with any exceptions, and the following:

6.1 Title of test

6.2 Sample description

6.3 Show calculation equating the fuel type to the required Btu/h thermal flux

6.4 Test equipment used, and date of last and next calibration

6.5 Fuel type

6.6 Values and observations, including observed discontinuities and leakage currents

6.7 Name of operator and date of test






Figure 1 – Thermocouple details



NOTES	mm	inch
	1	3.18
1	5.13	0.202
1	5.28	0.208
1	8.36	0.329
2	8.53	0.336
2	12.70	0.500
3	15.24	0.600
3	38.10	1.500
4	63.50	2.500
4	101.60	4.000
4	104.78	4.125
4	133.35	5.250
4	177.80	7.000
4	208.30	8.200
4	254.00	10.000


Figure 2 – Firewall connector fixture details

	mm	inch
--	----	------





DETAIL 'A'

3.18	0.125
4.83	0.190
6.35	0.250
12.70	0.500
25.40	1.000
31.75	1.250
177.80	7.000
208.28	8.200
254.00	10.000
279.40	11.000



DETAIL 'B'



NOTE — Dimensions are in inches. Unless otherwise specified, dimensions symmetrical about centerline.

Figure 3 – Firewall connector fixture assembly




Figure 4 – Firewall connector test setup




Figure 5 – Schematic circuit for testing firewall connectors

EIA Document Improvement Proposal

If in the review or use of this document, a potential change is made evident for safety, health or technical reasons, please fill in the appropriate information below and mail or FAX to:

Electronic Industries Alliance
Engineering Department – Publications Office
2500 Wilson Blvd.
Arlington, VA 22201
FAX: (703) 907-7501

Document No.	Document Title:
Submitter's Name:	Telephone No.: FAX No.: e-mail:
Address:	
Urgency of Change: Immediate: <input type="checkbox"/> At next revision: <input type="checkbox"/>	
Problem Area: a. Clause Number and/or Drawing: b. Recommended Changes: c. Reason/Rationale for Recommendation:	
Additional Remarks:	
Signature:	Date:
FOR EIA USE ONLY	
Responsible Committee:	
Chairman:	
Date comments forwarded to Committee Chairman:	

